

November 12, 2018

Via Website Posting: 1 Page

**ADDENDUM No. 5
Tender Call No. 283-2018**

**FOR: Installation of New Gas Stand-By Generator at Fire Hall 121 located at
10 William Carson Crescent, Toronto.**

CLOSING DATE: 12:00 NOON (LOCAL TIME), November 16, 2018

Please refer to the above Tender Call document in your possession and be advised of the following:

1.0 QUESTIONS & ANSWERS

1.1 *Question:*

In Section 16620: 2.6.6 – Is an SCR system with urea tank truly required?

Answer:

A: No, the SCR system with urea tank is not required for this project.

End of Addendum 5

Should you have any questions please contact Renato Buensuceso at (416) 392-4315, or by email Renato.Buensuceso@toronto.ca

Please attach this addendum to your Request for Tender document and be governed accordingly. Bidders must acknowledge receipt of all addenda on the space provided on the Tender Call Cover Page as per the Process Terms and Conditions, Section 1, Item 10 - Addenda, of the Tender Call document. All other aspects of the Tender remain the same.

Yours truly,

Joanne Kehoe, Manager
Construction Services
Purchasing and Materials Management