

Michael Pacholok, Chief Purchasing Officer

Purchasing and Materials Management  
City Hall  
19<sup>th</sup> Floor, West Tower  
100 Queen Street West  
Toronto, Ontario M5H 2N2

November 28, 2018

Via Internet Posting (2 pages)

**Addendum No. 2**  
**Request for Proposal No. 9119-18-5075**  
**Closing: 12:00 NOON (LOCAL TIME), December 4, 2018**

**For: Professional and Technical Services required to undertake Structural Condition Assessment Audit of All Parks, Forestry and Recreation Long-Span Roof Buildings**

Please refer to the above Request for Proposal (RFP) document in your possession and be advised of the following:

**1. Questions and Answers:**

**The following are responses to questions received during the call period:**

Q1) Is the assessment concerned only with the structural integrity of the long span trusses within each facility? Are we to review other area areas within facility as well, that don't have long span trusses?

**A1) *As per Addendum No 1 A15, the assessment relates to long span roof truss system that may include how it is supported.***

Q2) Section 3.2 sentence 5 – Are we ensuring that the roof span trusses meet the requirements of the current Ontario Building Code, or the building code that was in effect at the time of construction? Are we to include a lateral seismic investigation as well of the entire facility?

**A2) *Requirements to meet current edition of the Ontario Building Code. Lateral seismic investigation on the entire facility is not required.***

Q3) Section 3.2 sentence 7 - Are the detailed repair recommendations to include schematic drawings?

**A3) *Schematic drawings are not required.***

Q4) Section 3.2 (Data Collection) sentence 1 – For lifecycle costing, is a class 'D' budget estimate adequate?

**A4) *A class D budget estimate is adequate for lifecycle costing.***

Q5) Section 3.2 (Data Collection) sentence 2 – Are we required to create 'as-built' structural drawings for each facility?

**A5) *As-built drawing are not required.***

- Q6) How many of the 16 facilities in Phase One include long span wood trusses?
- A6) *This is to be determined by the successful proponent.***
- Q7) How many of the 28 facilities in Phase Two include long span wood trusses?
- A7) *This is to be determined by the successful proponent.***
- Q8) Section 3.2.9 – Role of Vendor refers to questionnaires. Are these existing documents or are they to be developed by the Vendor with City input?

Should you have any questions regarding this addendum contact Martin Suits by email at [Martin.Suits@toronto.ca](mailto:Martin.Suits@toronto.ca).

Please attach this addendum to your RFP document and be governed accordingly. Proponents must acknowledge receipt of all addenda in their Proposal in the space provided on the Proposal Submission Form as per Appendix A, Section 4 - Addenda of the RFP document. All other aspects of the RFP remain the same.

Yours truly,

Sabrina Dipietro  
Acting Manager, Construction Services  
Purchasing and Materials Management